

DESCRIPTION:

The **GEFCO Select #SE03-04 Cluster Jet** is typically used in participatory ornamental fountains and are finished units that allow the decorative presentation of a stream of water with a better than average stream quality containing some exceptional cohesion of the water presented. Minimum pipe size for manifolding of these jets is 3". A minimum debris strainer size of 3/16" is recommended.

TYPICAL SPECIFICATIONS:


- * **GEFCO Select #SE03-04 Cluster Jet:**
- made of machined brass.
- 1/2" NPT Inlet connection.
- 5/16" jet orifice.
- approx. 6" long.
- with integral flow straightener.
- adjustable +/- 15 degrees off of vertical

Replacement Parts:

- NONE

PERFORMANCE

SH	GAL	FH
05 FT	4.5	25
10 FT	7.0	45
15 FT	8.0	55
20FT	9.0	65



IMPORTANT NOTE

Designers and Engineers shall be responsible for the accuracy of system flow rates and especially system head loss requirements. Stated flows and head pressure requirements for any listed spray height are required AT THE NOZZLE. Extrapolations for unlisted spray heights are at the sole responsibility of the Designers and/or Engineers.

IMPORTANT

Dimensions, Manufacturers and/or Materials subject to change without notice